

Fire Department Water Tanker Shuttle Accreditation

Presented To: **Municipality of Clarington**

ACCREDITED FIRE STATIONS

Fire Station #1 Bowmanville
Fire Station #2 Newcastle
Fire Station #3 Orono
Fire Station #4 Courtice
Fire Station #5 Enniskillen

Date Test Passed: September 23, 2017

Flow Achieved: 645 I.G.P.M. 2930 LITERS/MIN.

Two (2) Hour Test Time

Signed: Peter J. Rose

Peter J. Rose, C.E.T., F.P.T.
Senior Fire Protection Specialist
Senior Loss Control Specialist

