



NOTES

1. STANDARD TO BE READ IN CONJUNCTION WITH C-501..
2. WIRE MESH TO BE ON PUBLIC SIDE OF GATE.
3. GATE FRAME TO BE CONSTRUCTED OF 42.8mm O.D. STEEL PIPE, GALVANIZED STEEL.
4. GATE TO OPEN ONTO PRIVATE PROPERTY.
5. ALL GATE COMPONENTS TO BE GALVANIZED SCHEDULE 40.
6. ALL WIRE FASTENERS TO BE 6 GAUGE ALUMINUM, OR HEAVIER.
7. GATE POSTS ARE TO BE 3.0m IN LENGTH.
8. SONOTUBES ARE TO BE USED FOR ALL FOOTINGS.
9. MAXIMUM 50mm GAP FROM CHAIN LINK FENCE TO GRADE BENEATH.

ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED



**GALVANIZED STEEL CHAIN LINK
SINGLE GATE (RESIDENTIAL)**

REVISION NO.: 1
REVISION DATE: DECEMBER 2025

C-502B